



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidadecounty.gov/pera](http://www.miamidadecounty.gov/pera)

**NOTICE OF ACCEPTANCE (NOA)**

Sulacer USA, Inc.  
6801 NW 77<sup>th</sup> Ave  
Miami, FL. 33166

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Altusa Barrel Made in Honduras**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews and revises NOA# 11-0812.05 and consists of pages 1 through 6.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 12-1203.03  
Expiration Date: 12/16/17  
Approval Date: 02/14/13  
Page 1 of 6

## ROOFING ASSEMBLY APPROVAL

**Category:** Roofing  
**Sub Category:** Roofing Tiles  
**Material:** Clay

### 1. SCOPE

This approves a roofing system using **Altusa 'Barrel' Made in Honduras**, as manufactured by **Sulacer, SA**, in **Honduras** and distributed by **Sulacer USA, Inc.** as described in Section 2 of this Notice of Acceptance. For locations where the pressure requirements, as determined by applicable Building Code does not exceed the design pressure values obtained by calculations in compliance with RAS 127 using the values listed in section 4 herein. The attachment calculations shall be done as a moment based system.

### 2. PRODUCT DESCRIPTION

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Altusa 'Barrel' Made in Honduras	l = 18" w = 8 1/2" 1/2" thick nominal	TAS 112	High profile, two-piece, clay roof tile. For mortar set or adhesive set applications with a nominal 2-1/2" headlap.
Trim Pieces	Length: varies Width: varies varying thickness	TAS 112	Accessory trim, clay roof pieces for use at hips, rakes, ridges and valley terminations. Manufactured for each tile profile.

#### 2.1 MANUFACTURING LOCATION

2.1.1. Pimienta Cortes, Honduras

#### 2.2 EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
American Test Lab of South Florida	RT0628.01-11	ASTM C 1167	07/12/11
American Test Lab of South Florida	RT0718.01-11	TAS 101	07/21/11
IBA Consultants, Inc. The Center for Applied Engineering, Inc.	2397-117 94-083	ASTM C 1167 Static Uplift Testing PA 101 (Adhesive Set)	06/28/07 April 1994
The Center for Applied Engineering, Inc.	257869-1	Static Uplift Testing PA 101 (Mortar Set)	Jan. 1997
Redland Technologies	P0647-01	Wind Tunnel Testing PA 108 (Mortar Set)	Aug. 1994
Walker Engineering, Inc.	Calculations	Aerodynamic Multiplier	March 1999
Walker Engineering, Inc.	Evaluation Calculations	25-7183	March 1995



NOA No.: 12-1203.03  
 Expiration Date: 12/16/17  
 Approval Date: 02/14/13  
 Page 2 of 6

## 2.2 EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Walker Engineering, Inc.	Evaluation Calculations	25-7094	February 1996
Walker Engineering, Inc.	Evaluation Calculations	25-7496	April 1996
Walker Engineering, Inc.	Evaluation Calculations	25-7584 25-7804b-8 25-7804-4 & 5 25-7848-6	December 1996

## 3. LIMITATIONS

- 3.1 Fire classification is not part of this acceptance.
- 3.2 For mortar or adhesive set tile applications, a static field uplift test shall be performed in accordance with TAS 106.
- 3.3 Applicant shall retain the services of a Miami-Dade County Certified Laboratory to perform quarterly test in accordance with TAS 112, appendix 'A'. Such testing shall be submitted to the Building Code Compliance Office for review.
- 3.4 Minimum underlayment shall be in compliance with the applicable Roofing Applications Standards listed section 4.1 herein.
- 3.5 30/90 hot mopped underlayment applications may be installed perpendicular to the roof slope unless stated otherwise by the underlayment material manufacturers published literature.
- 3.6 This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with applicable building code.
- 3.7 May be installed on slopes 7:12 and greater.



#### 4. INSTALLATION

4.1 Altusa 'Barrel' Made in Honduras tile and its components shall be installed in strict compliance with Roofing Application Standard RAS 120.

4.2 Data For Attachment Calculations

Tile Profile	Weight-W (lbf)	Length-l (ft)	Width-w (ft)
Altusa Barrel made in Honduras	4.5	1.5	0.71

Tile Profile	$\lambda$ (ft <sup>3</sup> ) Direct Deck Application
Altusa Barrel made in Honduras	0.24

Tile Profile	2":12"		3":12"		4":12"		5":12"		6":12"		7":12" or greater	
	Battens	Direct Deck	Battens	Direct Deck	Battens	Direct Deck	Battens	Direct Deck	Battens	Direct Deck	Battens	Direct Deck
Altusa Barrel made in Honduras	N/A	3.37	N/A	3.33	N/A	3.27	N/A	3.20	N/A	3.14	N/A	3.05

Tile Profile	Tile Application	Minimum Attachment Resistance
Altusa Barrel made in Honduras	3M™ 2-Component Foam Roof Tile Adhesive AH-160	177 (Clay tile) <sup>1</sup>
	Flexible TileBond	115 (Clay tile) <sup>2</sup>
	3M™ 2-Component Foam Roof Tile Adhesive AH-160	91.85 (Clay tile) <sup>3</sup>
1 Place 23 grams per pan and 23 grams per cap of AH-160.		
2 Place 11.8 grams per pan and 11.6 grams per cap of TileBond.		
3 Place 22.5 grams per pan and 14 grams per cap of AH-160.		

Tile Profile	Tile Application	Attachment Resistance
Altusa Barrel made in Honduras	Mortar Set	24.5 <sup>4</sup>
		213.8 <sup>5</sup>
4 Bermuda Roof TileTite mortar.		
5 Quickcrete Roof Tile Mortar # 1140.		



## 5. LABELING

All tiles shall bear the imprint or identifiable marking of the manufacturer's name or logo, or following statement: "Miami-Dade County Product Control Approved".

# ALTUSA MADE IN HONDURAS

IDENTIFICATION MARK FOR ALTUSA BARREL CLAY ROOF TILE  
LOCATED UNDERNEATH TILE

## 6. BUILDING PERMIT REQUIREMENTS

6.1 Application for building permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance.

6.1.2 Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this system.



NOA No.: 12-1203.03  
Expiration Date: 12/16/17  
Approval Date: 02/14/13  
Page 5 of 6